ASKER BIG 1306

Pobrano z mamadecor.pl

Asker big 1306XX0010
23.07.2021 v.10.9
www.norlys.com

Type of luminaire

Type of lumianire	Wall luminaire.
Photometric body	Double-sided light facing up and down.
Characteristics of the luminaire	A luminaire with a wide range of applications, for illuminating wall and facade surfaces and other architectural concepts

General information

Materials	Powder painted aluminum cast. Lens - transparent polycarbonate with structure, UV stabilized. Silicone gasket. EPDM cable gland.
Mounting method	Fixing the luminaire: intermediate plate, 2 adjustment holes 5x10mm, spacing 45mm, directly 2 holes ø5mm, spacing 68mm.
Terminal	Connection terminals: max 3x2,5mm², possibility to connect luminaire in loop max 3x1.5mm². Round insulated cable with a diameter of ø7...10,5mm.
Type of light source	LED module, power supply
Light control	Trailing edge dimming
Box dimensions [cm]	34,5x15x17

Technical data

4 LED modules.	Philips Strip OC 0.5ft 550lm 8xx FC LV5 (Datasheet)
Driver	Philips Xitanium 14W 0,35A 40V TE SC 230V (Datasheet)
Light source wattage	11,6 W
Luminaire wattage	13,7 W
Lamp luminous flux	2043lm
Luminaire luminous flux	1280lm
Light source efficiency	176,1lm/W
Efficiency of the luminaire	93,4lm/W
Color temperature	3000K
Colour consistency (McAdam ellipse)	SDCM3
Colour rendering index CRI	80
Rated life time L70/B50 at 25°C	>70 000h
LED photobiological threat	RG0 or RG1
Power Factor luminaire	PF > 0,95
THD factor	< 20%
Ta Rated temperature	+25°C
This product contains light sources of energy efficiency class	
Inrush current	1,87A/48µs

Files to download

Photometric LDT files	Photometric IES files
Manual	BIM Revit
BIM ArchiCAD	

Indexes

Index	Color	RAL
1306AL	ALUMINIUM	9006
1306B	BLACK	9005
1306GR	GRAPHITE	7016
1306W	WHITE	9003

Norlys AS
P.B 1014 Hoff, 0218 Oslo
Hovfaret 4B, 0275 Oslo
Norway
+47 24 12 40 11
firmapost@norlys.no

Please read the manual before installing it. Due to the dynamic development of lighting technology, additional information is available upon request. LED modules must be replaced by a qualified person in accordance with applicable regulations. Condensation, which can occur in luminaires, is a natural phenomenon and does not impair the quality of the luminaire