Pobrano z mamadecor.pl

LILLEHAMMER 1582

Lillehammer 1582XX0014
30.04.2021 v.14.8
www.norlys.com

Type of luminaire

Type of lumianire	Wall luminaire.
Photometric body	Single-sided light with 60° beam angle facing up or down.
Characteristics of the luminaire	Luminaire with a wide range of applications for example for illumination of walls and facade surfaces or any other architectural concepts.

General information

Materials	Powder painted aluminum cast. Lens - safety glass, optical. Silicone gasket. EPDM cable gland.
Mounting method	Fixing of the luminaire: 2 holes ø5mm, spacing 45x130mm.
Terminal	Connection terminals: max 3x2,5mm², possibility to connect luminaire in loop max 3x1,5mm². A round wire in the isolation with a diameter of max ø7...10,5mm.
Type of light source	LED module, power supply
Light control	Trailing edge dimming
Net / gross weight of luminaire	1,5kg / 1,5kg
Box dimensions [cm]	21x12,5x9,5

Technical data

LED module	Cree JK3030 no.1805004 (Datasheet)
Driver	Philips Xitanium 7W 0,35A 20V TE SC 230V (Datasheet)
Light source wattage	3W
Luminaire wattage	4,2W
Lamp luminous flux	435lm
Luminaire luminous flux	103lm
Light source efficiency	145lm/W
Efficiency of the luminaire	24,5lm/W
Color temperature	3000K
Colour consistency (McAdam ellipse)	SDCM3
Colour rendering index CRI	80
Rated life time L70/B50 at 25°C	50 000h
Power Factor luminaire	PF >0,9
Ta Rated temperature	+25°C

This product contains light source of energy efficiency class

Inrush current	1A/15,2µs

Maximum number of luminaires of this type per MCB:

B 10A: 157, **B 16A**: 250, **C 10A**: 260, **C 16A**: 425

Spare parts

46999560	LED module.
46999746	Power supply.

Files to download

Photometric LDT files	Photometric IES files
Manual	

Indexes

Index	Color	RAL
1582AL	ALUMINIUM	9006
1582B	BLACK	9005
1582GR	GRAPHITE	7016
1582W	WHITE	9003

Norlys AS
P.B 1014 Hoff, 0218 Oslo
Hovfaret 4B, 0275 Oslo
Norway
+47 24 12 40 11
firmapost@norlys.no

Please read the manual before installing. Due to the dynamic development of lighting technology, additional information is available upon request. LED module must be replaced by a qualified person in accordance with applicable regulations. Condensation, which can occur in luminaires, is a natural phenomenon and does not impair the quality of the luminaire.