ASKER 1700

Pobrano z mamadecor.pl

Asker 1700XX0010
23.07.2021 v.10.4
www.norlys.com

Type of luminaire

Type of lumianire	Wall luminaire.
Photometric body	Double-sided light facing up and down.
Characteristics of the luminaire	Luminaire with a wide range of applications for example for illumination of walls and facade surfaces or any other architectural concepts.

General information

Materials	Base - powder painted aluminum cast. Body - hot-dip galvanized steel Lens - transparent polycarbonate with structure, UV stabilized. Silicone gasket.
Mounting method	Fixing of the luminaire: 2 holes ø4,5mm, spacing 180x60mm.
Terminal	Connection terminals: max 3x2,5mm², possibility to connect luminaire in loop max 3x1,5mm². A round wire in the isolation with a diameter of max ø7...10,5mm.
Type of light source	LED module AC integrated
Light control	Phase-dimming (TRIAC).
Box dimensions [cm]	24x12x9,5

Technical data

LED module	Lumens EDC 57C 8W xxx 230V A FF Ver.1.0 (Datasheet)
Light source wattage	8W
Luminaire wattage	8W
Lamp luminous flux	890lm
Luminaire luminous flux	398lm
Light source efficiency	111,3lm/W
Efficiency of the luminaire	49,8lm/W
Color temperature	3000K
Colour consistency (McAdam ellipse)	SDCM3
Colour rendering index CRI	80
Rated life time L70/B50 at 25°C	50 000h
LED photobiological threat	RG0 or RG1
Power Factor luminaire	PF>0,99
THD factor	< 20%
Ta Rated temperature	+25°C
Max ambient temperature	-35...+25°C
This product contains light source of energy efficiency class	
Inrush current	2,9A/34µs

Spare parts

08151000	Gasket.
46999552	LED module.

Files to download

Photometric LDT files	Photometric IES files
Manual	BIM Revit
BIM ArchiCAD	

Indexes

Index	Color	RAL
1700GA	GALVANIZED	-

Norlys AS
P.B 1014 Hoff, 0218 Oslo
Hovfaret 4B, 0275 Oslo
Norway
+47 24 12 40 11
firmapost@norlys.no

Please read the manual before installing. Due to the dynamic development of lighting technology, additional information is available upon request. LED module must be replaced by a qualified person in accordance with applicable regulations. Condensation, which can occur in luminaires, is a natural phenomenon and does not impair the quality of the luminaire.