# ASKER 1707

Pobrano z mamadecor.pl

Asker 1707XX0010
23.07.2021 v.10.4
www.norlys.com

## Type of luminaire

| | |
|---|---|
| Type of lumianire | Wall luminaire. |
| Photometric body | Single-sided light facing down. |
| Characteristics of the luminaire | Luminaire with a wide range of applications for example for illumination of walls and facade surfaces or any other architectural concepts. |

## General information

| | |
|---|---|
| Materials | Base - powder painted aluminum cast. Body - hot-dip galvanized steel Lens - transparent polycarbonate with structure, UV stabilized. Silicone gasket. |
| Mounting method | Fixing of the luminaire: 2 holes ø4,5mm, spacing 180x60mm. |
| Terminal | Connection terminals: max 3x2,5mm², possibility to connect luminaire in loop max 3x1,5mm². A round wire in the isolation with a diameter of ø7...10,5mm. |
| Type of light source | E27 lamp |
| Box dimensions [cm] | 24x12x9,5 |

## Technical data

| | |
|---|---|
| E27 lamp | QA55 / LED A55..60 |
| Light source wattage | max 46W / LED 9W |
| Ta Rated temperature | +25°C |

This product contains light source of energy efficiency class

Possibility to order the luminaire with LED E27 Philips Master LEDbulb 806lm / 8,5W / 2700K (dimmable).

## Accessories sold separately

| | |
|---|---|
| 46999021 | LED E27 lamp. |

## Recommended light sources

| | |
|---|---|
| Osram LED Parathom Classic E27 | Philips Master LEDbulb / Ledbulb Classic E27 |
| Osram ECO PRO Classic 46<=>60W E27 | Philips ECO Classic 42<=>60W E27 |

## Files to download

| | |
|---|---|
| Photometric LDT files | Photometric IES files |
| Manual | BIM Revit |
| BIM ArchiCAD | |

## Indexes

| Index | Color | RAL |
|---|---|---|
| **1707GA** | GALVANIZED | - |

Norlys AS
P.B 1014 Hoff, 0218 Oslo
Hovfaret 4B, 0275 Oslo
Norway
+47 24 12 40 11
firmapost@norlys.no

Please read the manual before installing. Due to the dynamic development of lighting technology, additional information is available upon request. LED module must be replaced by a qualified person in accordance with applicable regulations. Condensation, which can occur in luminaires, is a natural phenomenon and does not impair the quality of the luminaire.