KOSTER 1914

Pobrano z mamadecor.pl

Koster 1914XX0309
23.07.2021 v.09.3
www.norlys.com

Type of luminaire

Photometric body	Single-sided, symmetric light facing down.
Characteristics of the luminaire	Classic design luminaire, mounted on a telescopic lighting pole. Adjustable height 2360..3360mm.

General information

Materials	Powder painted aluminum cast. Lens - transparent polycarbonate with structure, UV stabilized.
Mounting method	Fixing of the luminaire: 3 holes ø10,5mm, on a daimeter ø207mm every 120°. Set contains: Art. 1915 - luminaire, Art. 1273 - lightning pole. Other accessories need to be purchased separately.
Terminal	Connection terminal: max. 3x2,5mm², equipped with a fuse 1A 5x20. A round wire in the isolation with a diameter of max ø12,5mm.
Type of light source	LED module AC integrated
Light control	Non-dimmable luminaire
Net / gross weight of luminaire	9,42kg / 11,77kg
Side area of luminaire	0,01m^2

Technical data

LED module	Philips LED Fortimo DLM ES 2000/830 G2
Light source wattage	17,5W
Luminaire wattage	17,5W
Lamp luminous flux	1950lm
Luminaire luminous flux	1568lm
Light source efficiency	111,4lm/W
Efficiency of the luminaire	89,6lm/W
ULOR	0%
Color temperature	3000K
Colour consistency (McAdam ellipse)	SDCM3
Colour rendering index CRI	80
Rated life time L70/B50 at 25°C	50 000h
Power Factor luminaire	PF > 0,9
Ta Rated temperature	+25°C

This product contains light source of energy efficiency class

Inrush current	3,01A/32,66µs

Maximum number of luminaires of this type per MCB:

B 10A: 81, **B 16A**: 130, **C 10A**: 135, **C 16A**: 221

Accessories sold separately

111GA0009	Anchoring support.
405ZX0009	Concreting anchor.
406ZX0009	Ground anchor.

Spare parts

06710000	Lens.
46999751	LED module.

Files to download

Photometric LDT files	Photometric IES files
Manual	BIM Revit
BIM ArchiCAD	

Indexes

Index	Color	RAL
1914AL	ALUMINIUM	9006
1914GR	GRAPHITE	7016

Norlys AS
P.B 1014 Hoff, 0218 Oslo
Hovfaret 4B, 0275 Oslo
Norway
+47 24 12 40 11
firmapost@norlys.no

Please read the manual before installing. Due to the dynamic development of lighting technology, additional information is available upon request. LED module must be replaced by a qualified person in accordance with applicable regulations. Condensation, which can occur in luminaires, is a natural phenomenon and does not impair the quality of the luminaire.