NAMSOS 1931

Pobrano z mamadecor.pl

Namsos 1931XX0013
23.07.2021 v.13.7
www.norlys.com

Type of luminaire

Type of lumianire	Bollard.
Photometric body	Covered light facing down.
Characteristics of the luminaire	Modern design luminaire. For lighting gardens, private areas and public spaces

General information

Materials	Powder painted aluminum cast. Lens - safety glass, satin. Silicone gasket. EPDM cable gland.
Mounting method	Fixing of the luminaire: 4 holes ø10mm, spacing 61x121mm
Terminal	Connection terminals: max 3x4mm², possibility to connect luminaire in loop max 3x4mm². Round insulated cable with a diameter of max ø12,5mm
Type of light source	LED module, power supply
Light control	Trailing edge dimming
Net / gross weight of luminaire	9,04kg / 9,75kg
Box dimensions [cm]	27,5x15x97,5

Technical data

LED module	Philips Fortimo SLM C 1202 L06 1215 G7 (Datasheet)
Driver	Philips Xitanium 8W 0,2A 40V TE SC 230V (Datasheet)
Light source wattage	6,9W
Luminaire wattage	8,4W
Lamp luminous flux	890lm
Luminaire luminous flux	523lm
Light source efficiency	129lm/W
Efficiency of the luminaire	62,3lm/W
Color temperature	3000K
Colour consistency (McAdam ellipse)	SDCM3
Colour rendering index CRI	80
Rated life time L70/B50 at 25°C	>50 000h
LED photobiological threat	RG0 or RG1
Power Factor luminaire	PF 0,98
THD factor	< 20%
Ta Rated temperature	+25°C
Max ambient temperature	+40°C

This product contains light source of energy efficiency class

Inrush current	1,65A / 16,5µs

Accessories sold separately

112ZX0009	Concreting anchor
113GA0009	Ground anchor
114GA0009	Anchoring support

Spare parts

4699100701	LED module.
46999610	Power supply.
ZS1931zx0013	Electric set.

Files to download

Photometric LDT files	Photometric IES files
Manual	BIM Revit
BIM ArchiCAD	

Indexes

Index	Color	RAL
1931AL	ALUMINIUM	9006
1931GR	GRAPHITE	7016

Norlys AS
P.B 1014 Hoff, 0218 Oslo
Hovfaret 4B, 0275 Oslo
Norway
+47 24 12 40 11
firmapost@norlys.no



Please read the manual before installing it. Due to the dynamic development of lighting technology, additional information is available upon request. LED modules must be replaced by a qualified person in accordance with applicable regulations. Condensation, which can occur in luminaires, is a natural phenomenon and does not impair the quality of the luminaire.