Pobrano z mamadecor.pl

STAVANGER 5008

Stavanger 5008XX0011
23.07.2021 v.11.9
www.norlys.com

Type of luminaire

Type of lumianire	Bollard.
Photometric body	Indirect light with rotationally symmetrical light distribution facing down.
Characteristics of the luminaire	Bollard luminaire of stable and durable construction. For lighting private areas and public spaces

General information

Materials	Powder painted aluminum cast. Lens - clear polycarbonate, UV stabilized. Silicone gasket. Nylon6 cable gland.
Mounting method	Mounting of the luminaire: 3 holes ø9mm with a diameter of ø145mm every 120 °
Terminal	Connection terminals: max 3x4mm², Possibility to connect luminaire in loop max 3x2,5mm², Round insulated cable with a diameter of ø8...17mm
Type of light source	LED module, power supply
Light control	Trailing edge dimming
Net / gross weight of luminaire	11,03kg / 12,69kg
Box dimensions [cm]	22,5x22,5x103,5

Technical data

LED module	1305003G2 Cree XD16 4000K
Driver	Philips Xitanium 10W 0,5A 20V TE SC
Light source wattage	9,6W
Luminaire wattage	12,2W
Lamp luminous flux	1171lm
Luminaire luminous flux	493lm
Light source efficiency	122lm/W
Efficiency of the luminaire	40,4lm/W
Color temperature	4000K
Colour consistency (McAdam ellipse)	SDCM3
Colour rendering index CRI	80
Rated life time L70/B50 at 25°C	50 000h
Power Factor luminaire	PF > 0,98
Ta Rated temperature	+25°C

This product contains light source of energy efficiency class

Inrush current	3,36A / 36µs

Accessories sold separately

1230ZX0009	Concreting anchor
1231GA0009	Ground anchor
1232GA0009	Anchoring support

Spare parts

4699102101	LED module.
46999697	Power supply.

Files to download

Photometric LDT files	Photometric IES files
Manual	

Indexes

Index	Color	RAL
5008AL	ALUMINIUM	9006
5008GR	GRAPHITE	7016

Norlys AS
P.B 1014 Hoff, 0218 Oslo
Hovfaret 4B, 0275 Oslo
Norway
+47 24 12 40 11
firmapost@norlys.no

Please read the manual before the installation. Due to the dynamic development of lighting technology, additional information is available upon request. LED module must be replaced by a qualified person following applicable regulations. Condensation, which can occur in luminaires, is a natural phenomenon and does not impair the quality of the luminaire.