NORDLAND 5016

Pobrano z mamadecor.pl

Nordland 5016XX0013
23.07.2021 v.13.3
www.norlys.com

Type of luminaire

Type of lumianire	Wall/ceiling luminaire.
Photometric body	Diffused, uncovered light.
Characteristics of the luminaire	Plafon type luminaire with a modern design. For lighting private areas and other architectural concepts

General information

Materials	Powder painted aluminum cast. Lens - milky polycarbonate, UV stabilized. Silicone gasket. EPDM cable gland.
Mounting method	Mounting of the luminaire: 2 holes ø5mm, spacing 150x170mm
Terminal	Connection terminals: max 3x2.5mm², Possibility to connect the luminaire in loops, max 3x1.5mm². Round insulated cable with a diameter of ø7 ... 10.5mm
Type of light source	LED module AC integrated
Light control	Phase-dimming (TRIAC).
Net / gross weight of luminaire	2,25kg / 2,5kg
Box dimensions [cm]	30,5x30,5x11

Technical data

LED module	Lumens DLM 90C 10W xxx 230V /A V0.1 (Datasheet)
External control	Dimmers Lumens LED AC (User manual)
Light source wattage	10W
Lamp luminous flux	1120lm
Luminaire luminous flux	375lm
Light source efficiency	112lm/W
Color temperature	4000K
Colour consistency (McAdam ellipse)	SDCM3
Colour rendering index CRI	80
Rated life time L70/B50 at 25°C	50 000h
THD factor	< 20%
Ta Rated temperature	+25°C

This product contains light source of energy efficiency class

Optional version, deadline, and terms of production
after consulting with the Sales Department of Norlys Sp. z o.o.

Inrush current	150mA/500µs

Spare parts

06720002	Lens.
ZS5016zx0013	Service set.

Files to download

Photometric LDT files	Photometric IES files
Manual	BIM Revit
BIM ArchiCAD	

Indexes

Index	Color	RAL
5016AL	ALUMINIUM	9006
5016GR	GRAPHITE	7016
5016W	WHITE	9003

Norlys AS
P.B 1014 Hoff, 0218 Oslo
Hovfaret 4B, 0275 Oslo
Norway
+47 24 12 40 11
firmapost@norlys.no

Before the installation, read the instructions attached to the luminaire. Due to the dynamic development of lighting technology, we provide additional information at the client's request. LED module replaceable by a person with appropriate qualifications, following applicable regulations. Condensation, which may occur in luminaires, is a natural phenomenon and does not affect the quality of the luminaire