GENEVE 5108

Pobrano z mamadecor.pl

Geneve 5108XX0009
23.07.2021 v.09.7
www.norlys.com

Type of luminaire

Type of lumianire	Wall luminaire.
Photometric body	Double-sided light facing up and down.
Characteristics of the luminaire	Luminaire with a wide range of applications for example for illumination of walls and facade surfaces or any other architectural concepts.

General information

Materials	Powder painted aluminum cast. Lens - milky polycarbonate, UV stabilized. Silicone gasket. EPDM cable gland.
Mounting method	Fixing of the luminaire: 2 holes ø5mm, spacing 150x75mm.
Terminal	Connection terminals: max 3x2,5mm², possibility to connect luminaire in loop max 3x1,5mm². A round wire in the isolation with a diameter ø7...10,5mm.
Type of light source	LED module AC integrated
Light control	Phase-dimming (TRIAC).
Net / gross weight of luminaire	1,59kg / 1,96kg
Box dimensions [cm]	33x22x11

Technical data

LED module	Lumens EDC 57C 8W xxx 230V A FF Ver.1.0 (Datasheet)
External control	Dimmers Lumens LED AC (User manual)
Light source wattage	8W
Luminaire wattage	8W
Lamp luminous flux	961lm
Luminaire luminous flux	353lm
Light source efficiency	120,1lm/W
Efficiency of the luminaire	44,1lm/W
Color temperature	4000K
Colour consistency (McAdam ellipse)	SDCM3
Colour rendering index CRI	80
Rated life time L70/B50 at 25°C	50 000h
LED photobiological threat	RG0 or RG1
Power Factor luminaire	PF>0,99
THD factor	< 20%
Ta Rated temperature	+25°C
Max ambient temperature	-35...+25°C
This product contains light source of energy efficiency class	
Inrush current	2,9A/34µs

Spare parts

46999553	LED module.

Files to download

Photometric LDT files	Photometric IES files
Manual	BIM Revit
BIM ArchiCAD	

Indexes

Index	Color	RAL
5108AL	ALUMINIUM	9006
5108B	BLACK	9005
5108GR	GRAPHITE	7016
5108W	WHITE	9003

Norlys AS
P.B 1014 Hoff, 0218 Oslo
Hovfaret 4B, 0275 Oslo
Norway
+47 24 12 40 11
firmapost@norlys.no

Please read the manual before installing. Due to the dynamic development of lighting technology, additional information is available upon request. LED module must be replaced by a qualified person in accordance with applicable regulations. Condensation, which can occur in luminaires, is a natural phenomenon and does not impair the quality of the luminaire.